


DOGHOUSE VAULT











770.382.4462 sales@bartowprecast.com www.bartowprecast.com

120-61108 L1209-3636 R

PRODUCT INFORMATION 11'x8'x6' (ID) UTILITY VAULT

VAULT = 17,100 # LID = 7,450 #

SPECIFICATIONS MEETS ASTM C858 & C857

RATING: A-8 (H-10)

CONCRETE TO BE 4,000 PSI @ 28 DAYS

REINFORCING BAR MEETS ASTM A 615

10" STEPS ON 12" CENTERS

BUTYL SEALANT MEETING ASTM C 990 TO BE USED ON JOINTS

ACCESS HATCH SHALL BE FABRICATED WITH 1/4"
ALUMINUM DIAMOND PLATE DESIGNED TO SUPPORT 300 psf 36"x36" FRAME OPENING EQUIPPED WITH: SLAM LOCK, RECESSED LOCK BOX, FLUSH MOUNT LIFT HANDLE, HOLD-OPEN ARM, SS HARDWARE AND HINGES

DOGHOUSE SIZE & LOCATION MAY VARY UPON REQUEST

CALL FOR ADDITIONAL SPECS



DRAWING INFORMATION

| Date: | Revision: | Checked By: | Drawn By: |
|--------------------|-----------|-------------|-----------|
| $\frac{7/21/11}{}$ | <u> </u> | CBC | JJG |

APPROVED BY:

| eign. | print: | |
|-------|--------|--|
| | | |
| | | |
| | | |

sign: