


## 7'x5'x5' (ID) DOGHOUSE VAULT













sales@bartowprecast.com 770.382.4462 WWW.BARTOWPRECAST.COM

## 120-50705 L0806-3636 R

PRODUCT INFORMATION
7'x5'x5' (ID)
UTILITY VAULT

VAULT = 9,150 # LID = 2,950 #

SPECIFICATIONS MEETS ASTM C858 & C857

RATING: A-8 (H-10)

CONCRETE TO BE 4,000 PSI @ 28 DAYS

REINFORCING BAR MEETS ASTM A 615

10" STEPS ON 12" CENTERS

BUTYL SEALANT MEETING ASTM C 990 TO BE USED ON JOINTS

ACCESS HATCH SHALL BE FABRICATED WITH 1/4"
ALUMINUM DIAMOND PLATE DESIGNED TO SUPPORT 300 psf 36"x36" FRAME OPENING EQUIPPED WITH: SLAM LOCK, RECESSED LOCK BOX, FLUSH MOUNT LIFT HANDLE, HOLD-OPEN ARM, SS HARDWARE AND HINGES

DOGHOUSE SIZE & LOCATION MAY VARY UPON REQUEST

CALL FOR ADDITIONAL SPECS



## DRAWING INFORMATION

| Date:   | Revision: | Checked By: | Drawn By: |
|---------|-----------|-------------|-----------|
| 7/18/11 | 1         |             | JJG       |

APPROVED BY:

|  | , |
|--|---|
|  | 1 |
|  | ١ |
|  | 1 |
|  |   |
|  |   |
|  | ı |
|  | ١ |
|  | ı |
|  | ì |
|  |   |
|  |   |
|  |   |

sign: print: